

Certificate



Certificate no.

T 50551884 01

License Holder:

GLORIA GmbH
Diestedder Str. 39
59329 Wadersloh
Germany

Manufacturing Plant:

040-0002254113

Test report no.: DONGELIN CN21UKI7 002

Client Reference:

Tested to: EN 14604:2005
EN 14604:2005/AC:2008

Certified Product: (Photoelectric Smoke Alarm)


License Fee - Units

Type Designation: R-1 (GLORIA)
Sensor Type : Photoelectric, using Transmitted Light
Mounting : Ceiling or Wall
Rated Voltage : DC 9.0V
(Replaceable battery: 1) DURACELL: MN1604, MX1604;
2) GOLD PEAK: 1604A, 1604S, 1604P;
3) ENERGIZER: 522)
Battery Life : > 1 years

10

Remark: Not suitable for installation in leisure accommodation Vehicles.

10



Licensed Test mark:



TÜV Rheinland (China) Ltd.

Signature

Date of Issue

(day/mo/yr)

17/08/2022

A. Chen

TÜV Rheinland (China) Ltd.

Room 301, 3F and Room 1203, 12F, Building 4, No. 15, Ronghua South Road, Beijing Economic-Technological Development Area, Beijing (Yizhuang group in high-end industrial area of Beijing Pilot Free Trade Zone), P.R. China